



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Mapleton Elementary School
1642 Main Street
Mapleton, ME 04757

Date Printed: 04/08/2022
Work Order #: 2203-00981
Client Job #: 552
Date Received: 03/08/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/08/2022
CLIENT NAME: Mapleton Elementary School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 1642 Main Street
 Mapleton, ME 04757

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/08/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 552

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00981-001	Cafeteria	I	DWF	03/06/2022 01:17PM	<1	ppb			DR-NH	04/07/2022 09:47PM
2203-00981-002	2nd Grade Hall	I	DWF	03/06/2022 01:19PM	<1	ppb			DR-NH	04/07/2022 09:50PM
2203-00981-003	5th Grade Hall	I	DWF	03/06/2022 01:21PM	<1	ppb			DR-NH	04/07/2022 09:59PM
2203-00981-004	Main Office Hall	I	DWF	03/06/2022 01:22PM	<1	ppb			DR-NH	04/07/2022 10:02PM
2203-00981-005	Gymnasium	I	DWF	03/06/2022 01:23PM	<1	ppb			DR-NH	04/07/2022 10:10PM
2203-00981-006	Room 1	I	OT	03/06/2022 01:29PM	5.6	ppb			DR-NH	04/07/2022 10:13PM
2203-00981-007	Room 3	I	OT	03/06/2022 01:30PM	8.8	ppb			DR-NH	04/07/2022 10:16PM
2203-00981-008	Room 4	I	OT	03/06/2022 01:30PM	1.7	ppb			DR-NH	04/07/2022 10:19PM
2203-00981-009	Room 5	I	OT	03/06/2022 01:31PM	5.9	ppb			DR-NH	04/07/2022 10:22PM
2203-00981-010	Room 6	I	OT	03/06/2022 01:31PM	92.2	ppb			DR-NH	04/07/2022 10:25PM
2203-00981-011	Room 7	I	OT	03/04/2022 01:32PM	7.9	ppb			DR-NH	04/07/2022 10:28PM
2203-00981-012	Room 8	I	OT	03/04/2022 01:32PM	3.3	ppb			DR-NH	04/07/2022 10:31PM
2203-00981-013	Room 9	I	OT	03/04/2022 01:33PM	129	ppb			DR-NH	04/07/2022 10:48PM
2203-00981-014	Room 10	I	OT	03/06/2022 01:33PM	2.2	ppb			DR-NH	04/07/2022 10:51PM
2203-00981-015	Room 11	I	OT	03/06/2022 01:34PM	20.0	ppb			DR-NH	04/07/2022 10:54PM
2203-00981-016	Room 12	I	OT	03/06/2022 01:34PM	3.8	ppb			DR-NH	04/07/2022 10:57PM
2203-00981-017	Room 13	I	OT	03/06/2022 01:35PM	3.2	ppb			DR-NH	04/07/2022 11:00PM
2203-00981-018	Room 14	I	OT	03/06/2022 01:36PM	34.8	ppb			DR-NH	04/07/2022 11:02PM
2203-00981-019	Room 15	I	OT	03/06/2022 01:36PM	16.1	ppb			DR-NH	04/07/2022 11:05PM
2203-00981-020	Teachers Lounge	I	OT	03/06/2022 01:27PM	<1	ppb			DR-NH	04/07/2022 11:08PM
2203-00981-021	AV Center East	I	OT	03/06/2022 01:25PM	8.5	ppb			DR-NH	04/07/2022 11:11PM
2203-00981-022	AV Center West	I	OT	03/06/2022 01:24PM	2.4	ppb			DR-NH	04/07/2022 11:14PM
2203-00981-023	Kitchen Sink #1	I	KF	03/06/2022 01:15PM	<1	ppb			DR-NH	04/07/2022 11:29PM
2203-00981-024	Kitchen Sink #2	I	KF	03/06/2022 01:15PM	<1	ppb			DR-NH	04/07/2022 11:32PM
2203-00981-025	Kitchen Sink #3	I	KF	03/06/2022 01:16PM	<1	ppb			DR-NH	04/07/2022 11:34PM
2203-00981-026	Kitchen Sink #4	I	KF	03/06/2022 01:16PM	<1	ppb			DR-NH	04/07/2022 11:37PM

Rebecca L. Labranche
 Laboratory Director