



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Pine Street Elementary School
50 Pine Street
Presque Isle, ME 04769

Date Printed: 04/08/2022
Work Order #: 2203-00976
Client Job #: 553
Date Received: 03/08/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/08/2022
CLIENT NAME: Pine Street Elementary School

CLIENT ADDRESS: 50 Pine Street
 Presque Isle, ME 04769

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/08/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 553

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00976-001	Room 1	I	OT	03/05/2022 12:15PM	1.2	ppb			DR-NH	04/06/2022 10:04PM
2203-00976-002	Room3	I	OT	03/05/2022 12:15PM	4.7	ppb			DR-NH	04/06/2022 10:16PM
2203-00976-003	Room 5	I	OT	03/05/2022 12:16PM	9.8	ppb			DR-NH	04/06/2022 10:19PM
2203-00976-004	Room 7	I	OT	03/05/2022 12:16PM	<1	ppb			DR-NH	04/07/2022 08:40PM
2203-00976-005	Room 9	I	OT	03/05/2022 12:17PM	5.0	ppb			DR-NH	04/06/2022 10:22PM
2203-00976-006	Room 11	I	OT	03/05/2022 12:17PM	2.2	ppb			DR-NH	04/06/2022 10:25PM
2203-00976-007	Room 16	I	OT	03/05/2022 12:18PM	13.5	ppb			DR-NH	04/06/2022 10:28PM
2203-00976-008	Room 18	I	OT	03/05/2022 12:19PM	1.8	ppb			DR-NH	04/06/2022 10:31PM
2203-00976-009	Room23	I	OT	03/05/2022 12:20PM	<1	ppb			DR-NH	04/06/2022 10:39PM
2203-00976-010	Room 25	I	OT	03/05/2022 12:20PM	<1	ppb			DR-NH	04/06/2022 10:42PM
2203-00976-011	Room 27	I	OT	03/05/2022 12:21PM	5.0	ppb			DR-NH	04/06/2022 10:51PM
2203-00976-012	Room 29	I	OT	03/05/2022 12:21PM	<1	ppb			DR-NH	04/06/2022 10:54PM
2203-00976-013	Room 31	I	OT	03/05/2022 12:22PM	1.9	ppb			DR-NH	04/06/2022 10:57PM
2203-00976-014	Room 32	I	OT	03/05/2022 12:22PM	3.4	ppb			DR-NH	04/06/2022 11:00PM
2203-00976-015	Room 33	I	OT	03/05/2022 12:23PM	2.9	ppb			DR-NH	04/06/2022 11:03PM
2203-00976-016	Room 34	I	OT	03/05/2022 12:23PM	5.6	ppb			DR-NH	04/06/2022 11:05PM
2203-00976-017	Room 35	I	OT	03/05/2022 12:24PM	1.5	ppb			DR-NH	04/06/2022 11:08PM
2203-00976-018	Room 36	I	OT	03/05/2022 12:24PM	2.1	ppb			DR-NH	04/06/2022 11:11PM
2203-00976-019	Room 37	I	OT	03/05/2022 12:25PM	2.7	ppb			DR-NH	04/07/2022 09:15PM
2203-00976-020	Room 39	I	OT	03/05/2022 12:25PM	593	ppb			DR-NH	04/07/2022 08:43PM
2203-00976-021	Gymnasium	I	DWF	03/05/2022 12:14PM	<1	ppb			DR-NH	04/07/2022 09:18PM
2203-00976-022	Cafeteria	I	DWF	03/05/2022 12:13PM	<1	ppb			DR-NH	04/07/2022 09:21PM
2203-00976-023	Kitchen Sink #1	I	KF	03/05/2022 12:12PM	2.8	ppb			DR-NH	04/07/2022 09:24PM
2203-00976-024	Kitchen Sink #2	I	KF	03/05/2022 12:12PM	<1	ppb			DR-NH	04/07/2022 09:35PM
2203-00976-025	Kitchen Sink #3	I	KF	03/05/2022 12:11PM	<1	ppb			DR-NH	04/07/2022 09:38PM
2203-00976-026	Kitchen Sink #4	I	KF	03/05/2022 12:11PM	<1	ppb			DR-NH	04/07/2022 09:41PM

Rebecca L. Labranche
 Laboratory Director





A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/08/2022
CLIENT NAME: Pine Street Elementary School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 50 Pine Street
 Presque Isle, ME 04769

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/08/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 553

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00976-027	Kitchen Tilt Skillet	I	KF	03/05/2022 12:10PM	<1	ppb			DR-NH	04/07/2022 09:44PM



Rebecca L. Labranche
 Laboratory Director