



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Presque Isle High School
16 Griffin Street
Presque Isle, ME 04769

Date Printed: 04/11/2022
Work Order #: 2203-00995
Client Job #: 557
Date Received: 03/08/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/11/2022
CLIENT NAME: Presque Isle High School

CLIENT ADDRESS: 16 Griffin Street
Presque Isle, ME 04769

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/08/2022 09:20AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 557

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00995-001	Cafeteria	I	DWF	03/06/2022 06:30AM	<1	ppb			DR-NH	04/08/2022 01:51AM
2203-00995-002	Senior Hall 100 Wing	I	DWF	03/06/2022 06:12AM	<1	ppb			DR-NH	04/08/2022 01:54AM
2203-00995-003	Sophomore Hall 200 Wing	I	DWF	03/06/2022 06:08AM	<1	ppb			DR-NH	04/08/2022 01:56AM
2203-00995-004	Junior Hall by Nurses Office	I	DWF	03/06/2022 06:28AM	<1	ppb			DR-NH	04/08/2022 01:59AM
2203-00995-005	Concessions Hall	I	DWF	03/06/2022 06:22AM	2.2	ppb			DR-NH	04/08/2022 02:02AM
2203-00995-006	Upper Gymnasium	I	DWF	03/06/2022 06:43AM	<1	ppb			DR-NH	04/08/2022 02:05AM
2203-00995-007	kitchen Sink #1	I	KF	03/06/2022 06:31AM	<1	ppb			DR-NH	04/08/2022 02:08AM
2203-00995-008	Kitchen Sink #2	I	KF	03/06/2022 06:32AM	<1	ppb			DR-NH	04/08/2022 04:55PM
2203-00995-009	Kitchen Sink #3	I	KF	03/06/2022 06:33AM	<1	ppb			DR-NH	04/08/2022 04:58PM
2203-00995-010	Kitchen Tilt Skillet	I	KF	03/06/2022 06:30AM	3.1	ppb			DR-NH	04/08/2022 05:01PM
2203-00995-011	Kitchen Ice Machine	I	OT	03/06/2022 06:31AM	<1	ppb			DR-NH	04/08/2022 05:04PM
2203-00995-012	Room 128 Life Skills Kitchenette	I	KF	03/06/2022 06:29AM	<1	ppb			DR-NH	04/08/2022 05:07PM
2203-00995-013	Main Office	I	OT	03/06/2022 06:16AM	2.1	ppb			DR-NH	04/08/2022 05:10PM
2203-00995-014	Senior Hall Teachers Lounge	I	OT	03/06/2022 06:14AM	1.0	ppb			DR-NH	04/07/2022 08:46PM
2203-00995-015	Nurses Office Sink #1	I	OT	03/06/2022 06:26AM	<1	ppb			DR-NH	04/08/2022 05:13PM
2203-00995-016	Nurses Office Sink #2	I	OT	03/06/2022 06:27AM	112	ppb			DR-NH	04/08/2022 05:16PM
2203-00995-017	Art Room	I	OT	03/06/2022 06:20AM	<1	ppb			DR-NH	04/08/2022 05:27PM
2203-00995-018	Room 300	I	OT	03/06/2022 06:40AM	3.5	ppb			DR-NH	04/08/2022 05:30PM
2203-00995-019	Room 226	I	OT	03/06/2022 06:04AM	3.6	ppb			DR-NH	04/08/2022 05:39PM
2203-00995-020	Room 228	I	OT	03/06/2022 06:02AM	<1	ppb			DR-NH	04/08/2022 05:42PM
2203-00995-021	Room 230	I	OT	03/06/2022 06:00AM	9.0	ppb			DR-NH	04/08/2022 05:45PM
2203-00995-022	Library Hall Teachers Lounge	I	OT	03/06/2022 06:10AM	2.2	ppb			DR-NH	04/08/2022 05:48PM
2203-00995-023	Room 223	I	OT	03/06/2022 06:06AM	6.1	ppb			DR-NH	04/08/2022 05:51PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/11/2022
CLIENT NAME: Presque Isle High School
CLIENT ADDRESS: 16 Griffin Street
 Presque Isle, ME 04769
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 03/08/2022 09:20AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 557

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00995-024	Lower Gym Phys Ed Office	I	OT	03/06/2022 06:46AM	<1	ppb			DR-NH	04/08/2022 05:54PM
2203-00995-025	Superintendents Break Room	I	OT	03/06/2022 06:42AM	6.5	ppb			DR-NH	04/08/2022 06:02PM
2203-00995-026	Upper Gym Phys Ed Office	I	OT	03/06/2022 06:44AM	<1	ppb			DR-NH	04/08/2022 06:05PM

Rebecca L. Labranche
 Laboratory Director