



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Presque Isle Middle School
569 Skyway Street
Presque Isle, ME 04769

Date Printed: 04/07/2022
Work Order #: 2203-00973
Client Job #: 556
Date Received: 03/08/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/07/2022
CLIENT NAME: Presque Isle Middle School

CLIENT ADDRESS: 569 Skyway Street
Presque Isle, ME 04769

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/08/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #: 556

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00973-001	6th Grade Hall	I	DWF	03/06/2022 10:30AM	<1	ppb			DR-NH	04/06/2022 08:34PM
2203-00973-002	8th Grade Hall	I	DWF	03/06/2022 10:34AM	<1	ppb			DR-NH	04/06/2022 08:37PM
2203-00973-003	Fine Arts Hall	I	DWF	03/06/2022 10:37AM	<1	ppb			DR-NH	04/06/2022 08:40PM
2203-00973-004	Cafeteria	I	DWF	03/06/2022 10:38AM	1.4	ppb			DR-NH	04/06/2022 08:43PM
2203-00973-005	Gymnasium	I	DWF	03/06/2022 10:39AM	<1	ppb			DR-NH	04/06/2022 08:46PM
2203-00973-006	Main Office Hall	I	DWF	03/06/2022 10:53AM	<1	ppb			DR-NH	04/06/2022 08:49PM
2203-00973-007	Room 1	I	OT	03/06/2022 10:52AM	<1	ppb			DR-NH	04/06/2022 08:52PM
2203-00973-008	Room 6	I	OT	03/06/2022 10:50AM	<1	ppb			DR-NH	04/06/2022 09:03PM
2203-00973-009	Room 14	I	OT	03/06/2022 10:49AM	5.6	ppb			DR-NH	04/06/2022 09:06PM
2203-00973-010	Room 29 Life Skills Kitchennette	I	KF	03/06/2022 10:45AM	5.0	ppb			DR-NH	04/06/2022 09:15PM
2203-00973-011	KITCHEN Sink #	I	KF	03/06/2022 10:42AM	<1	ppb			DR-NH	04/06/2022 09:18PM
2203-00973-012	Kitchen Sink #2	I	KF	03/06/2022 10:42AM	<1	ppb			DR-NH	04/06/2022 09:21PM
2203-00973-013	Kitchen Sink #3	I	KF	03/06/2022 10:43AM	<1	ppb			DR-NH	04/06/2022 09:24PM
2203-00973-014	Kitchen Sink #4	I	KF	03/06/2022 10:43AM	<1	ppb			DR-NH	04/06/2022 09:27PM
2203-00973-015	Kitchen Sink #5	I	KF	03/06/2022 10:44AM	<1	ppb			DR-NH	04/06/2022 09:29PM
2203-00973-016	Room 201	I	OT	03/06/2022 10:59AM	<1	ppb			DR-NH	04/06/2022 09:38PM
2203-00973-017	Room 202	I	OT	03/06/2022 11:01AM	<1	ppb			DR-NH	04/06/2022 09:41PM
2203-00973-018	Room 218	I	OT	03/06/2022 11:03AM	1.1	ppb			DR-NH	04/06/2022 09:44PM
2203-00973-019	Main Hall Teachers Lounge	I	OT	03/06/2022 10:48AM	<1	ppb			DR-NH	04/06/2022 09:47PM
2203-00973-020	7th Grade Teachers Lounge	I	OT	03/06/2022 10:58AM	<1	ppb			DR-NH	04/06/2022 09:56PM
2203-00973-021	8th Grade Teachers Lounge	I	OT	03/06/2022 10:55AM	<1	ppb			DR-NH	04/06/2022 09:59PM
2203-00973-022	Ice machine	I	OT	03/06/2022 10:46AM	<1	ppb			DR-NH	04/06/2022 10:01PM

Rebecca L. Labranche
Laboratory Director